



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511CL0362

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Distributor <i>Vertreiber</i>	Kembla HK Ltd. 5/F Henan Building, 90 Jaffe Road, HK- Wanchai
Product Category <i>Produktart</i>	installation systems and system joints: pipe joint for pipes in drinking water installation systems (8511)
Product Description <i>Produktbezeichnung</i>	compression and transition connectors made of unleaded silicon copper alloy, type M-MM, for copper pipes acc. to DVGW GW 392 and stainless steel pipes acc. to DVGW GW 541 (1.4404 and 1.4521)
Model <i>Modell</i>	KEMPRESS SILICON BRONZE PRESS FITTINGS
Test Reports <i>Prüfberichte</i>	laboratory control test: 120002507-19 from 15.01.2020 (MPM) type testing: 120004360-2 from 17.04.2015 (MPM) type testing: 120004360-1 from 17.04.2015 (MPM) mechanical test: 120002507-14 from 24.09.2014 (MPM) supplement test: 120004161 from 25.09.2013 (MPM) supplement test: 120004022 from 26.09.2012 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 534-(P) (01.07.2015) DVGW CERT ZP 8500 (09.03.2017) UBA METALLE (21.11.2018) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	31.08.2025 / 20-0369-WNR

03.11.2020 GI B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 15,0 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 18,0 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 22,0 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 28,0 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 35,0 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 42,0 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 54,0 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 64,0 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 66,7 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 76,1 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 88,9 mm	
KEMPRESS SILICON BRONZE PRESS FITTINGS	diameter: 108,0 mm	

Type Variation Ausführungsvariante	Explanations Erläuterungen
KEMPRESS SILICON BRONZE PRESS FITTINGS	Female Tee: 22,0x1/2", 28,0x1/2", 28,0x3/4", 35,0x1/2", 42,0x1/2"
KEMPRESS SILICON BRONZE PRESS FITTINGS	Male Coupling: 15,0x1/2", 15,0x3/4", 22,0x1/2", 22,0x3/4", 28,0x3/4", 28,0x1", 35,0x1 1/4", 42,0x1 1/2", 54,0x2", 66,7x2 1/2", 76,1x3", 108,0x4"
KEMPRESS SILICON BRONZE PRESS FITTINGS	Female Coupling: 15,0x1/2", 15,0x3/4", 22,0x1/2", 22,0x3/4", 28,0x3/4", 28,0x1", 35,0x1 1/4", 42,0x1 1/2", 54,0x2", 66,7x2 1/2", 76,1x3"
KEMPRESS SILICON BRONZE PRESS FITTINGS	Wallplate Elbow: 15,0x1/2", 22,0x3/4"
KEMPRESS SILICON BRONZE PRESS FITTINGS	90° Elbow Female Coupling: 15,0x1/2", 15,0x3/4", 22,0x1/2", 22,0x3/4", 22,0x1", 28,0x1/2", 28,0x3/4", 28,0x1", 35,0x1 1/4", 42,0x1 1/2", 54,0x2"
KEMPRESS SILICON BRONZE PRESS FITTINGS	90° Elbow Male Coupling: 15,0x1/2", 15,0x3/4", 22,0x1/2", 22,0x3/4", 22,0x1", 28,0x1", 35,0x1 1/4", 42,0x1 1/2", 54,0x2"
KEMPRESS SILICON BRONZE PRESS FITTINGS	Union Adaptor: 15,0x3/4", 22,0x3/4", 76,1x3"

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

only to use with the following pipes:

pipes made of stainless steel:

-according to DVGW-working sheet GW 541 (1.4404, table 2 and 3) for the diameters 15.0 - 108.0 mm

-according to DVGW-working sheet GW 541 (1.4521, table 2 and 3) for the diameters 15.0 - 108.0 mm

-diameter 66.7 mm according to DIN EN 10312 - row 1

pipes made of copper:

-according to DVGW-working sheet GW 392 for the diameters 15.0 - 108.0 mm

-diameter 66.7 mm according to DIN EN 1057 (hard)